


**NOTES**

1. APPROVED BACKFLOW ASSEMBLY SHALL BE INSTALLED SUCH THAT IT IS READILY ACCESSIBLE FOR REPAIR AND INSPECTION.
2. BRASS FITTINGS, VALVES AND PIPE SHALL CONSIST OF LOW-LEAD BRASS ALLOY AND SHALL HAVE A MINIMUM WORKING PRESSURE OF 150 PSI.
3. BRASS OR PLASTIC PLUGS SHALL BE INSTALLED ON ALL TEST PORTS.
4. ALL ABOVE GROUND PIPE, FITTINGS AND ASSEMBLY SHOULD BE PAINTED WITH TWO COATS OF ENAMEL.
5. AN ENCLOSURE OR CAGE MAY BE INSTALLED AT THE OPTION OF THE PROPERTY OWNER.



**CITY OF SANTA CRUZ**

**WATER DEPARTMENT**  
CITY OF SANTA CRUZ, CALIFORNIA

**DETAIL 8**  
**2-INCH AND SMALLER BACKFLOW PREVENTION ASSEMBLY INSTALLATION**

NOT TO SCALE

APPROVED *[Signature]*

RCE 37391